

**Environmental  
Protection Agency**

John E. Kasicki, Governor  
Deborah Taylor, Lt. Governor  
Scott M. Staley, Director

August 17, 2011

RE: WAYNE COUNTY  
CHIPPEWA TWP  
OAK PARK MHP  
3PV00015

Mr. Gerald Apel  
Oak Park MHP  
14740 Oak Grove Drive  
Doylestown, OH 44230

Dear Mr. Apel:

On August 8, 2011, this writer conducted a compliance evaluation inspection of the sewage treatment plant serving your facility. Denny White represented your facility during the inspection.

The existing sewage treatment system consists of a trash trap, extended aeration, final clarifiers, sand filter beds, chlorination/dechlorination contact tank. The system discharges to Pancake Creek.

At the time of the inspection, the treatment plant was in good operation. The system was producing what appeared to be a satisfactory effluent.

A review of your Discharge Monitoring Reports (DMRs) covering the period July 2010 through July 2011 revealed the following effluent violations.

| Reporting Period | Parameter               | Limit Type | Limit | Reported Value | Violation Date |
|------------------|-------------------------|------------|-------|----------------|----------------|
| October 2010     | Nitrogen, Ammonia (NH3) | 30D Conc   | 2.0   | 7.198          | 10/1/2010      |
| October 2010     | Nitrogen, Ammonia (NH3) | 30D Qty    | 0.2   | .40848         | 10/1/2010      |
| October 2010     | Nitrogen, Ammonia (NH3) | 7D Conc    | 3.0   | 14.3           | 10/8/2010      |
| October 2010     | Nitrogen, Ammonia (NH3) | 7D Qty     | 0.3   | .81188         | 10/8/2010      |
| November 2010    | pH                      | 1D Conc    | 9.0   | 9.8            | 11/10/2010     |
| November 2010    | Total Suspended Solids  | 7D Conc    | 18    | 19.            | 11/22/2010     |
| April 2011       | Nitrogen, Ammonia (NH3) | 7D Conc    | 9.0   | 9.3            | 4/8/2011       |
| May 2011         | Fecal Coliform          | 30D Conc   | 1000  | 2100.          | 5/1/2011       |
| May 2011         | Dissolved Oxygen        | 1D Conc    | 6.0   | 5.             | 5/11/2011      |
| May 2011         | Fecal Coliform          | 7D Conc    | 2000  | 2100.          | 5/15/2011      |
| May 2011         | Dissolved Oxygen        | 1D Conc    | 6.0   | 4.             | 5/18/2011      |
| May 2011         | Total Suspended Solids  | 7D Conc    | 18    | 19.            | 5/22/2011      |
| May 2011         | CBOD 5 day              | 7D Conc    | 15    | 18.            | 5/22/2011      |
| June 2011        | Total Suspended Solids  | 30D Conc   | 12    | 13.25          | 6/1/2011       |
| June 2011        | Total Suspended Solids  | 7D Conc    | 18    | 22.            | 6/8/2011       |
| June 2011        | Total Suspended Solids  | 7D Qty     | 1.70  | 1.84859        | 6/8/2011       |

Mr. Gerald Apel  
Oak Park MHP  
August 17, 2011  
Page 2

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,

A handwritten signature in black ink, appearing to read "Todd Surrena". The signature is fluid and cursive, with the first name "Todd" being more prominent than the last name "Surrena".

Todd Surrena  
Engineering Geologist  
Division of Surface Water

TMS/mt

cc: Denny White, Operator

File: Semi-Public/Wayne/ChippewaTwp/OakParkMHP