



**Environmental
Protection Agency**

John Kasich, Governor
Robert Taft, Lt. Governor
Michael DeWine, Director

July 2, 2010

RE: TRUMBULL COUNTY
WARREN TOWNSHIP
PLEASANT PARK MOBILE HOME PARK
NPDES PERMIT NO. OH0107522
OHIO EPA PERMIT NO. 3PV00067

Mr. Leo Chiarullo, Owner
Pleasant Park Mobile Home Park
5029 Parkman Road
Warren, Ohio 44481

Dear Mr. Chiarullo:

On June 15, 2010, an inspection was conducted at the above referenced facility by Ms. Charlotte Hammar and the undersigned. No one was available at the office during the posted business hours. The purpose of the inspection was to evaluate the facility's compliance status with respect to the terms and conditions of the NPDES permit.

The wet-stream treatment components consist of a flow equalization basin, 22,500 gpd extended aeration activated sludge treatment process, final settling tank, slow surface sand filtration, chlorine disinfection, and dechlorination. Sludge handling consists of an aerated sludge holding tank and sludge drying beds.

At the time of the inspection, the following observations, findings, and/or comments were noted:

- The general operation and maintenance of the treatment plant appear to be satisfactory. However, there did appear to be some water leakage around the aeration tanks. Please have this situation investigated by your operator and provide a follow-up notice to this office.
- The final effluent being discharged to the receiving stream appeared to be of satisfactory visual quality.
- The facility needs to make improvements to the fencing to prevent unauthorized access to the facility.
- In accordance with Ohio Administrative Code (OAC) 3745-7, the facility must provide written notice regarding the name and certification of the designated operator(s) of record for the facility. Please complete the enclosed Operator of Record (ORC) Notification Form and return it to the specified address within 30 days of receipt of this letter.

Mr. Leo Chiarullo
Pleasant Park Mobile Home Park
July 2, 2010
Page 2

Discharge monitoring reports (DMR) received by Ohio EPA for the period January 2009 through May 2010, were reviewed for compliance with the final effluent limitations and monitoring requirements of the NPDES permit. No effluent violations were noted at Outfall 001.

Please be advised that failure to comply with the terms and conditions of your NPDES permit may be subject to enforcement actions pursuant to Chapter 6111 of the Ohio Revised Code. Such actions can result in fines of up to \$10,000 per day of violation. Please be advised that past or present issues of noncompliance can continue as subjects of future enforcement actions by Ohio EPA.

Should you have any questions or comments regarding this letter, please contact this office.

Respectfully,



Ermelindo Gomes
Environmental Engineer
Division of Surface Water

EG/mt

Enclosure: ORC Form

cc: Valley Environmental Lab