



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 24, 2007

RE: TRUMBULL COUNTY  
WARREN TOWNSHIP  
PLEASANT PARK MOBILE HOME PARK  
NPDES PERMIT NO. OH0107522  
OHIO EPA PERMIT NO. 3PV00067

Mr. Leo Chiarullo, Owner  
Pleasant Park Mobile Home Park  
5029 Parkman Road  
Warren, OH 44481

Dear Mr. Chiarullo:

On August 23, 2007, an inspection was conducted at the above referenced facility by the undersigned. The facility was represented by your son, Mr. Tom Chiarullo. The purpose of the inspection was to evaluate the facility's compliance status with respect to the terms and conditions of the National Pollutant Discharge Elimination System (NPDES) permit.

The wet-stream treatment components consist of a flow equalization basin, 22,500-gpd extended aeration activated sludge treatment process, final settling tank, slow surface sand filtration, chlorine disinfection, and dechlorination. Sludge handling consists of an aerated sludge holding tank and sludge drying beds.

At the time of the inspection, the following observations were noted and discussed with Mr. Chiarullo:

1. The sand filters were being bypassed at the dosing line union connection. As referenced in Part III, Paragraph 11, of the NPDES permit, bypassing or diverting of wastewater around treatment components is prohibited. Mr. Chiarullo was instructed to replace the union with a permanent, i.e. glued, connection.
2. The general upkeep of the treatment plant area appears to have improved.
3. The walls of the surface sand filters still need to be repaired to acceptable operating condition.
4. The missing guards on the influent pump station motors still need to be replaced.

A review of the facility's monthly operating reports received by Ohio EPA for the period May 2006 through August 2007 indicates violations of the terms and conditions contained in the NPDES permit. The specific instances of noncompliance are as follows:


Mr. Leo Chiarullo  
Pleasant Park Mobile Home Park  
September 24, 2007  
Page 2

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
April 2007	001	Dissolved Oxygen	1D Conc	5.0	3.5	4/24/2007
July 2007	001	Dissolved Oxygen	1D Conc	5.0	4.2	7/19/2007

Please be advised that failure to comply with the terms and conditions of your NPDES permit may be subject to enforcement actions pursuant to Chapter 6111 of the Ohio Revised Code. Such actions can result in fines of up to \$10,000 per day of violation. Please inform this office, in writing, within 10 days of receipt of this notification as to the actions taken or proposed to address the above violation and/or deficiencies. Your response **shall** include specific dates for completion of the actions. Please be advised that past or present issues of noncompliance can continue as subjects of future enforcement actions by Ohio EPA.

Should you have any questions or comments regarding this letter, please contact this office.

Respectfully,



Ermelindo Gomes  
Environmental Engineer  
Division of Surface Water

EG/mt

cc: Valley Environmental Services