



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korieski, Director

January 4, 2011

RE: WAYNE COUNTY
EAST UNION TWP
WHISPERING PINES MHP
NPDES #3PV00101

NOTICE OF VIOLATION

CERTIFIED MAIL

Mr. Joseph LaMonica
Whispering Pines MHP
6658 Palmer Drive
Canton, Ohio 44718

Dear Mr. LaMonica:

On January 3, 2011, this writer spoke with you via phone regarding the compliance status of your wastewater treatment plant serving the Whispering Pines MHP. As stated to you during the conversation, your wastewater treatment plant is in significant noncompliance with its NPDES permit.

Your NPDES permit became effective on June 1, 2007. The schedule of compliance, Part I, C, requires you to submit detail plans for wastewater treatment plant upgrades. The required upgrades included a sludge holding tank. According to the compliance schedule of your NPDES permit, the detail plans for the upgraded wastewater treatment plant were required to be submitted by December 1, 2007 and the upgrades were required to be installed by June 1, 2008. To date, these detail plans have not been submitted. You are currently in noncompliance with your NPDES permit for failing to comply with your compliance schedule.

A review of your discharge monitoring reports covering the period March 1, 2007 through December 31, 2010, revealed that your facility has not been submitting data. Not submitting discharge monitoring reports is a violation of your NPDES permit.

Ohio EPA has reviewed your compliance as it relates to your NPDES permit. You are directed to inform this office, in writing, as to when a permit-to-install application will be submitted to Ohio EPA for the upgrades. Also, include in this letter the name of your licensed operator and your plan for submitting discharge monitoring reports. Failure to comply with the conditions of your NPDES permit will result in this matter being referred to our legal section for an enforcement action.

Should you have any comments or questions regarding this letter, please contact this office at (330) 963-1255.

Respectfully,

Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/mt

cc: Wayne County Health Department

File: Semi-Public/Wayne/E. Union Twp/Whispering Pines MHP

Discharge Monitoring Violations:

Reporting Period	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2008	00515	Residue, Total Dissolv	1D Conc	1500	3180.	8/22/2008
October 2008	00515	Residue, Total Dissolv	1D Conc	1500	2820.	10/24/2008
November 2008	00515	Residue, Total Dissolv	1D Conc	1500	2330.	11/25/2008
December 2008	00515	Residue, Total Dissolv	1D Conc	1500	2730.	12/19/2008
January 2009	00515	Residue, Total Dissolv	1D Conc	1500	4610.	1/23/2009
February 2009	00515	Residue, Total Dissolv	1D Conc	1500	1770.	2/27/2009
March 2009	00515	Residue, Total Dissolv	1D Conc	1500	4840.	3/20/2009
April 2009	00515	Residue, Total Dissolv	1D Conc	1500	5450.	4/17/2009
March 2009	00530	Total Suspended Solids	30DConc	12	14.	3/1/2009
March 2009	00530	Total Suspended Solids	30DConc	30	48.	3/1/2009
March 2009	00530	Total Suspended Solids	1D Conc	45	48.	3/26/2009

7010 1060 0000 0089 5205

U.S. POSTAL SERVICE
CERTIFIED MAIL RECEIPT

For more information visit our website at www.usps.com

[Empty rectangular box]

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Sent To

Street, Apt. No.,
or PO Box No.

City, State, ZIP+4

Instructions