



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 20, 2011

RE: WAYNE COUNTY  
WOOSTER TWP  
FORREST VIEW MHP  
NPDES #3PV00125

Mr. Matt Madigan  
P.O. Box 548  
Smithville, Ohio 44677

Dear Mr. Madigan:

A compliance evaluation inspection of the waste water treatment plant serving the Forrest View Mobile Home Park was conducted by this writer on January 19, 2011. Present during the inspection was Leo Miller, The Apple Creek Banking Co., and yourself.

The wastewater treatment plant was installed under a Permit to Install (PTI) issued by Ohio EPA on December 27, 2006. The 12,000 gallon per day plant consists of a flow EQ tank, trash trap, extended aeration tanks, clarifier, dosing station, two surface sand filters, chlorination and dechlorination, and a 2,500 gallon sludge holding tank. The system discharges to unnamed tributary of Apple Creek.

At the time of the inspection, the treatment plant was in good operation. There was good air flow into the aeration tanks, sludge return lines were operating, the clarifier weir was clean, the dosing pumps were operating, and the sand beds were debris free. The sand filter splitter box was leaking between the box and discharge pipe. The leak was due to a faulty seal between the box and pipe. You stated that the freezing temperatures had cracked the seal around the pipe and this item would be repaired as soon as the weather allowed. The treatment system was producing what appeared to be a satisfactory effluent.

As stated in a January 4, 2011 notice of violation letter, Ohio EPA has reviewed your compliance as it relates to your NPDES permit. According to Ohio EPA records, you have not submitted discharge monitoring reports covering the period January 1, 2009 through December 31, 2010. By not submitting the discharge monitoring reports, you are in violation of your NPDES permit.


You stated during the inspection that you have been in contact with James Roberts of the Ohio EPA about using the Division of Surface Water Electronic Discharge Monitoring Report Submission System. You stated that Mr. Roberts directed you on how to use the system. You stated that you would begin using the system immediately.

Mr. Matt Madigan  
Forrest View MHP  
January 20, 2011  
Page 2

To prevent further enforcement action by Ohio EPA, you must begin submitting DMR every month.

Should you have any comments or questions regarding this letter, please contact this office at (330) 963-1255.

Respectfully,

A handwritten signature in black ink, appearing to read "Todd Surrena". The signature is written in a cursive style with a large, looping initial "T".

Todd Surrena  
Engineering Geologist  
Division of Surface Water

TMS/mt

cc: Wayne County Health Department  
Leo Miller, The Apple Creek Banking Co., Apple Creek Office

File: Semi-Public/Wayne/Wooster Twp/Forrest View MHP