



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

October 18, 2010

Shane Clark  
Del-Co Water Company Inc  
6658 Olentangy River Road  
Delaware, OH 43015

**Re: Construction Storm Water Inspection at Del-Co Water Company Inc.  
Delaware County  
Permit Number: 4GCO00033\*AG**

Dear Mr. Clark:

This letter is written regarding a storm water inspection conducted by Stephen Riley of the Ohio EPA at Del-Co Water Company Inc located at 6658 Olentangy River Road Delaware, Ohio on September 30, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The detention basin noted onsite must be modified to address sediment control via the installation of a pond skimmer or an approved alternative. This will allow for additional settling time for the suspended solids to settle prior to a final discharge from the site.
- It was noted that the silt fence adjacent to the parking lot had not yet been entrenched. Mr. Riley was assured by the contractor on site that this would be completed for the end of the business day.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Del-Co Water Company Inc. 9-30-2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

