

**Environmental
Protection Agency**

Governor
Lt. Governor
Director

October 17, 2011

RE: STARK COUNTY
NIMISHILLEN TOWNSHIP
NORTHMARK PROPERTIES
7349 RAVENNA AVE.
NPDES NO. 3PR00468

CERTIFIED MAIL

Mr. Stephen C. Coon
Coon Restoration & Sealants, Inc.
7349 Ravenna Ave. NE
P.O. Box 259
Louisville, OH 44641

Dear Mr. Coon:

On September 22, 2011, this office conducted an inspection of the wastewater treatment system serving the above referenced facility.

The existing sewage treatment system consists of a trash trap followed by a 1,500-gallon per day extended aeration treatment plant, dosing chamber, surface sand filter and chlorine contact tank with a tablet chlorinator and dechlorinator. The system discharges to an unnamed tributary to the East Branch Nimishillen Creek.

At the time of the inspection the following observations were made:

- 1) The plant was on and being aerated.
- 2) The sludge and skimmer returns were functioning.
- 3) The contents of the clarifier were light brown.
- 4) The sand filters were clean and level.

A review of your Discharge Monitoring Reports (DMRs) covering the period September 2010 through August 2011 indicates that you have not been submitting electronic Discharge Monitoring Report (eDMR) since February 2011. This is a very serious violation of your National Pollutant Discharge Elimination System (NPDES) and is subject to an enforcement action. You are required to provide a written explanation to this office no later than October 31, 2011, as to why you have failed to submit the required monitoring. Failure to do so may result in the initiation of the enforcement action to seek civil and monetary penalties as allowed under Ohio Revised Code 6111.

NORTHMARK PROPERTIES
 NPDES NO. 3PR00468
 OCTOBER 17, 2011
 PAGE 2 OF 2

Should you have any questions or comments regarding this letter, please contact this office at (330)963-1136 or by e-mail at phil.rhodes@epa.state.oh.us.

Sincerely,




Philip P. Rhodes, P.E.
 Environmental Specialist II
 Division of Surface Water

PR/cs

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Northmark Properties

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY	
<ul style="list-style-type: none"> Complete Items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. Print your name and address on the reverse so that we can return the card to you. Attach this card to the back of the mailpiece, or on the front if space permits. 	A. Signature 	<input type="checkbox"/> Agent <input type="checkbox"/> Addressee
1. Article Addressed to: MR. STEPHEN C. COON COON RESTORATION & SEALANTS, INC. 7349 RAVENNA AVE. NE P.O. BOX 259 LOUISVILLE, OH 44641	B. Received by (Printed Name) 	C. Date of Delivery
2. Article Number (Transfer from service label) 7008 3230 00035419 6283	D. Is delivery address different from item 1? <input type="checkbox"/> Yes If YES, enter delivery address below: <input type="checkbox"/> No	
PS Form 3811, February 2004	3. Service Type <input type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.	
Domestic Return Receipt	4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes	
102595-02-M-1540	Rhodes 10/21/11	