

**Environmental
Protection Agency**

**Governor
Lt. Governor
Director**

October 17, 2010

RE: STARK COUNTY
NIMISHILLEN TOWNSHIP
CARRIAGE HOUSE
9033 COLUMBUS RD.
NPDES NO. 3PR00479

Michael Ritchie
Robert King
Precision Holdings, LLC
591 Noel Street
Louisville, OH 44641

Dear Mr. Ritchie:

On September 22, 2010, this writer conducted a Compliance Evaluation Inspection (CEI) of your wastewater treatment plant located at 9033 Columbus Road. Below you will find a summary of visual observations made during the inspection:

- 1) The plant was being properly aerated and the mixed liquor inside the aeration tank exhibited a good chocolate brown color.
- 2) The sludge and skimmer returns were operating.
- 3) The surface sand filters need to be cleaned and raked level.
- 4) Noted was that the chlorination/dechlorination tank has been installed and a proper sampling point has been installed. Please inform this office as to the date the facilities were operational for our records.

A review of your electronic Discharge Monitoring Reports (eDMR) covering the period August 2010 thru August 2011 revealed the following violations of your National Pollutant Discharge Elimination System (NPDES) permit:

Numeric Violations

<u>Station</u>	<u>Parameter</u>	<u>Limit Type</u>	<u>Limit</u>	<u>Reported Value</u>	<u>Violation Date</u>
001	Total Suspended Solids	30D Conc	12	44.	6/1/2011
001	Total Suspended Solids	30D Qty	0.23	.24981	6/1/2011
001	Total Suspended Solids	7D Conc	18	44.	6/8/2011

Frequency violations

Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
001	Chlorine, Total Residu	1/Quarter	1	0	06/01/2011
001	Total Suspended Solids	1/Quarter	1	0	08/01/2011
001	Nitrogen, Ammonia (NH3)	1/Quarter	1	0	08/01/2011
001	Fecal Coliform	1/Quarter	1	0	08/01/2011
001	CBOD 5 day	1/Quarter	1	0	08/01/2011
001	pH	1/Quarter	1	0	08/01/2011
001	Dissolved Oxygen	1/Quarter	1	0	08/01/2011
001	Chlorine, Total Residu	1/Quarter	1	0	08/01/2011

You are required by the NPDES permit to notify this office when you experience violations of the NPDES permit in accordance with Part III, Section 12. Failure to provide this notification is an additional violation for each occurrence.

Additionally, you have not transferred the NPDES permit to your corporation and therefore you have no authorization to discharge from the treatment plant. **This was brought to your attention in our April 5, 2010 letter and needs to be resolved immediately.**

Should you have any questions or comments regarding this letter, please feel free to contact this office at (330)963-1136.

Sincerely,



Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PR/cs

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Carriage House