


John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

November 2, 2012

Gary Spanner
5800 Griffiths Lane
Powell, OH 43065

Franklin County
Countryside MHP
Community Water System
PWS ID: OH2500612

Dear Public Water System Owner:

The Public Water System serving Countryside Mobile Home Park is in violation of the Ohio Administrative Code (OAC) for:

Language for Sanitary Survey (SS) Violations

Failure to respond in Writing within 30 days

This letter is notification that the Countryside Mobile Home Park has not complied with requirements issued during this Agency's last survey performed on September 18, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated September 26, 2012, to respond in writing no later than 30 days, with time frames for:


- a. Filling in the area around the well casing such that the ground slopes away from it.
- b. Installing bollards around the well casing for protection against vehicular damage.
- c. Requirements 1 -7 as specified in the September 26, 2012 letter.

Provide a written response to each item in the September 26, 2012 survey letter within 10 days of the date of this letter. Another copy of the letter can be provided upon request.

Gary Spanner
Page -2-

If you have any questions please call me at (614) 728-3864.

Sincerely,

A handwritten signature in black ink that reads "Carolyn O'Neal". The signature is written in a cursive style with a horizontal line underlining the first name.

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

c: DDAGW AA (State Violation)
ec: eDoc
District Inspector

CO/ct 2500612(SS)Oct2012