

**Environmental
Protection Agency**

**Governor
Lt. Governor
Director**

OH2801312 HOLLY HILL NURSING HOME

24 09/26/11



NOTICE OF VIOLATION – ACTION REQUIRED

September 28, 2011

RE: GEAUGA COUNTY
HOLLY HILL NURSING HOME
COMMUNITY WATER SYSTEM
PWS ID: OH2801312

Mr. Ronald L Durkee
P.O. Box 337
Newbury, OH 44065

Subject: Failure to Sample Drinking Water for Total Coliforms as Required

Dear Mr. Durkee:

Holly Hill Nursing Home is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

Monitoring Period: August 2011
Required Coliform Monitoring: 5 routines per Month
Sample Results Submitted: 4

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

ACTION REQUIRED:

1. **Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

Timing: As soon as practical, but no later than one year after learning of the violation:

- Mail or other direct delivery to each customer; OR
- Annual Consumer Confidence Report provided it's distributed within one year after learning of the violation; and
- If necessary to reach all persons regularly served, use other notification methods such as newspaper publication, public posting or Internet posting;
- Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.

2. **Complete the enclosed Verification Form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

HOLLY HILL NURSING HOME
SEPTEMBER 28, 2011
PAGE 2

If total coliform samples were collected as required, submit the results as soon as possible. The monitoring violation would be rescinded and a reporting violation given for late submittal of the results.

If you have any questions, contact this office at 330-963-1149.

Sincerely,



Kathy Metropulos
Environmental Specialist
Division of Drinking and Ground Waters

KM:ds

enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

cc: Geauga County Health Department
Information Management Section, DDAGW, CO
District Office File