

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH7604612 RIDGE MOBILE HOME PARK

22 06/16/11



NOTICE OF VIOLATION – ACTION REQUIRED

June 16, 2011

RE: STARK COUNTY
RIDGE MOBILE HOME PARK
COMMUNITY WATER SYSTEM
PWS ID: OH7604612

Mr. Richard Lawrence
3708 Parkhill Circle NW
Canton, OH 44718

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During June 2011**

Dear Mr. Lawrence:

Ridge Mobile Home Park is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:


1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Mail or other direct delivery to each customer;
 - If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

RIDGE MOBILE HOME PARK
JUNE 16, 2011
PAGE 2

4. Monitor with at least five (5) routine samples in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 330-963-1236.

Sincerely,



David J. Bowland
Environmental Specialist
Division of Drinking and Ground Waters

DJB:dms

enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Stark County Health Department
Information Management Section, DDAGW, CO
District File Copy