

**Environmental
Protection Agency**

Governor
Lt. Governor
Director

OH7733512 LIFE CENTER PLUS FITNESS CENTER

53 08/10/11



August 10, 2011

RE: SUMMIT COUNTY
LIFE CENTER PLUS FITNESS CENTER
NTNC WATER SYSTEM
PWS ID #OH7733512
LEAD AND COPPER

VIOLATION NOTIFICATION

Mr. Dan Roberts
Life Center Plus Fitness Center
5133 Darrow Road
Hudson, OH 44236

Subject: Failure to Perform and Submit Water Quality Parameters/Corrosion Control Recommendation/Source Water Treatment Recommendation/Detail Plans for Corrosion Control Equipment

Dear Mr. Roberts:

This letter is notification that the Life Center Plus Fitness Center water system is in violation of the Ohio Administrative Code (OAC) for failure to perform lead and copper Water Quality Parameter and Entry Point Monitoring, and for failure to submit a Corrosion Control/Source Water Treatment Recommendation and Detail Plans as specified in OAC Rules 3745-81-80 through 3745-81-89.

In order to avoid any further violations, you must complete the following:

1. Within 30 days, monitor with a minimum of two samples for each applicable water quality parameter from:
 - A. Each entry point to the distribution system; and
 - B. One site in the distribution system.

The parameters to measure are pH, water temperature, alkalinity, calcium, conductivity, orthophosphate (when a phosphate inhibitor is used), and silica (when a silicate-containing inhibitor is used).

In addition, monitor with a minimum of one sample for lead and copper at each entry point to the distribution system. Report the results to us on the enclosed Form 5108 within 30 days.

LIFE CENTER PLUS FITNESS CENTER
AUGUST 10, 2011
PAGE 2 OF 2

Issue the enclosed public notice and return a copy and the verification form to this office within 30 days.

2. Submit the required Corrosion Control Recommendation and Detail Plans for optimal corrosion control treatment and equipment no later than September 30, 2011.
3. Submit a Source Water Treatment Recommendation no later than September 30, 2011.

If you have any questions regarding this letter, please contact me at (330) 963-1227.

Sincerely,



Ursula Musselman
Environmental Specialist
Division of Drinking and Ground Waters

UM:ds

enclosures: 5108 Form, 141-C Form, Public Notice and Verification Form

cc: Ohio EPA, IMS-DDAGW, CO
Kim Eppers, Ohio EPA, DDAGW, NEDO
Dan Underwood, Ohio EPA, DDAGW, NEDO