

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH7783212 HALE FARM - CHURCH

21 05/19/11 A



NOTICE OF VIOLATION – ACTION REQUIRED

May 19, 2011

RE: SUMMIT COUNTY
HALE FARM - CHURCH
NON-COMMUNITY, TRANSIENT
PWS ID: OH7783212

CERTIFIED MAIL

Mr. Jason Klein
2686 Oak Hill Road
P.O. Box 296
Bath, OH 44210

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During April-June 2011 (ACUTE)**

Dear Mr. Klein:

Hale Farm - Church is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Water samples have confirmed the presence of *E. colif* fecal coliform in the drinking water. *Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes.* This is an Acute MCL violation requiring immediate action.

IMMEDIATE ACTION REQUIRED:

- 1. Consult with Ohio EPA within 24 hours** regarding public notice requirements. If you have not already received direction regarding this violation, contact the NEDO at 330-963-1227.
- 2. Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.
 - Hand delivery to persons served by the water system
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas
 - Send to parents or guardians of children at schools or day care facilities
 - Another delivery method approved in writing by the director
 - Posted notices must remain in place for as long as the violation exists.
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

NOTE: Issuance of a Public Notice must be repeated every 30 days for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice stating the corrective measures completed to date must be submitted to the Ohio EPA.

Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924

330 | 963 1200
330 | 487 0769 (fax)
www.epa.ohio.gov

3. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
4. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.
5. **Discontinue the Water Use Advisory** – The water use advisory shall remain in effect until one set of four (4) repeat samples is total coliform-negative. Notify the people served by the water system when the water use advisory is discontinued.
6. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact Ursula Musselman at 330-963-1227.

Sincerely,



Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR:dms

enclosures: Tier 1 Public Notification
Public Notice Instructions and Verification Form

cc: Summit County Health Department
Information Management Section, Ohio EPA, DDAGW, CO
Ursula Musselman, Ohio EPA, DDAGW, NEDO
Kim Eppers, Ohio EPA, DDAGW, NEDO