



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH7854712 JOSEPH BADGER LOCAL SCHOOL PWS

22 07/01/11



NOTICE OF VIOLATION – ACTION REQUIRED

July 1, 2011

RE: TRUMBULL COUNTY
JOSEPH BADGER LOCAL SCHOOL PWS
NON-TRANSIENT NON-COMMUNITY
PWS ID # OH7854712

Mr. David Bair
7119 State Route 7
Kinsman, OH 44428

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During June 2011 and Failure to Sample Source Water for Fecal Indicators**

Dear Mr. Bair:

Joseph Badger Local School PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

Joseph Badger Local School PWS is also in violation of Ohio Administrative Code (OAC) 3745-81-42 for failure to comply with the Ground Water Rule monitoring requirements.

To address this violation, return to compliance, and prevent federal enforcement action, the required source water samples must be collected. Failure to collect the required source water sample(s) may result in enforcement action by the United States Environmental Protection Agency (USEPA). If source water (raw) samples were collected as required, submit the results to the appropriate Ohio EPA District Office as soon as possible. If raw water sample was not collected, they must still be collected and Ohio EPA must receive result to return to compliance and prevent referring this violation to USEPA.

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notices in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;

JOSEPH BADGER LOCAL SCHOOL PWS
JULY 1, 2011
PAGE 2

- Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notices** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.
 4. **Monitor with at least five (5) routine samples** in the month following (July 2011) a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 330-963-1242.

Sincerely,



Charlotte E. Hammar
Environmental Specialist
Division of Drinking and Ground Waters

CEH/ams

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Trumbull County Health Department
Information Management Section, DDAGW, CO
Kim Etters, DDAGW, NEDO