



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

OH7804512 PLALAN LAKE WATER ASSOC.

23 02/23/11



**NOTICE OF VIOLATION – ACTION REQUIRED**

February 23, 2011

RE: TRUMBULL COUNTY  
PLALAN LAKE WATER ASSOC.  
COMMUNITY WATER SYSTEM  
PWS ID: OH7804512

Ms. Pamela Monroe  
P.O. Box 214  
West Farmington, OH 44491

**Subject: Failure to Sample Drinking Water for Total Coliforms as Required**

Dear Ms. Monroe:

Plalan Lake Water Assoc. is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

**Monitoring Period:** January 2011  
**Required Coliform Monitoring:** 1 routine per Month  
**Sample Results Submitted:** 0

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

**ACTION REQUIRED:**

- 1. Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

**Timing:** As soon as practical, but no later than one year after learning of the violation:

- Mail or other direct delivery to each customer; OR
- Annual Consumer Confidence Report provided it's distributed within one year after learning of the violation; and
- If necessary to reach all persons regularly served, use other notification methods such as newspaper publication, public posting or Internet posting;
- Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.


- 2. Complete the enclosed Verification Form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

PLALAN LAKE WATER ASSOC.  
FEBRUARY 23, 2011  
PAGE 2

If total coliform samples were collected as required, submit the results as soon as possible. The monitoring violation would be rescinded and a reporting violation given for late submittal of the results.

**Please return a copy of BOTH the public notice and the verification form to this office** at the letterhead address or fax the completed forms to fax # (330) 963-4760. If you have any questions, contact me at 330-963-1242.

Sincerely,



Charlotte E. Hammar  
Environmental Specialist  
Division of Drinking and Ground Waters

CEH:dms

enclosures: Tier 3 Public Notification  
Public Notice Instructions & Verification Form

cc: Trumbull County Health Department  
Information Management Section, DDAGW, CO  
District Office File