



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**

October 20, 2011



NOTICE OF VIOLATION – ACTION REQUIRED

Mr. William Law
6270 TR 208,
Loudonville, OH 44842

HOLMES COUNTY
ARROWPOINT CAMPGROUND-WEST
NON-COMMUNITY, TRANSIENT PWS
PWS ID # OH3846712

Subject: Failure to Conduct Required Repeat Total Coliform and Ground Water Rule Monitoring

Dear Mr. Law:

Arrowpoint Campground-West is in violation of monitoring requirements for Total Coliform established by Ohio Administrative Code (OAC), Rules 3745-81-21 and 3745-81-42 for October-December 2011.

Ohio EPA records indicate that a total coliform-positive sample was collected from this water system on 10/6/2011 and the required repeat samples were not collected. For your water system the four repeat samples also satisfy the Ground Water Rule requirement for the initial raw water sample. To ensure the safety of drinking water provided by your system monitoring with all of the required repeat samples is essential.

IMMEDIATE ACTION REQUIRED:

- 1. Consult with Ohio EPA within 24 hours** regarding sampling and public notice requirements. If you have not already received direction regarding this violation, contact the NEDO at 330-963-1121.
- 2. Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.
 - Hand delivery to persons served by the water system;
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Send to parents or guardians of children at schools or day care facilities;
 - Another delivery method approved in writing by the director;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

NOTE: Issuance of a Public Notice must be repeated every 30 days for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice, stating the corrective measures completed to date, must be submitted to the Ohio EPA.

3. **Complete the enclosed verification form, within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.
4. **Collect a set of four (4) repeat samples, until one set is total coliform-negative to discontinue the Water Use Advisory.** Notify the people served by the water system when the water use advisory is discontinued.
5. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

According to our records, Arrowpoint Campground-West is closed for the season and unable to collect the required samples. Therefore, your water system will remain on a boil alert and you will be required to collect the four (4) repeat samples and five (5) routine samples when you reopen in April 2012. Your public notice must remain in place until all required sampling is completed and the boil alert is lifted.

If repeat samples were collected, submit them as soon as possible.

If you have any questions, contact Leonard Rychlik at 330-963-1121.

Sincerely,

A handwritten signature in black ink, appearing to read "Nancy N. Rice", followed by the word "for" written in a similar cursive style.

Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR/ams

Enclosures: Tier 1 Public Notification
Public Notice Instructions and Verification Form

cc: Holmes County Health Department
Information Management Section, Ohio EPA, Central Office, DDAGW
Leonard Rychlik, Ohio EPA, NEDO, DDAGW
Kim Ethers, Ohio EPA, NEDO, DDAGW