



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, Lt. **Governor**
Scott J. Nally, **Director**



October 11, 2011

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Ron Johnson
Hanoverton Church of Christ
9833 State Route 9
Hanoverton, OH 44423

COLUMBIANA COUNTY
HANOVERTON CHURCH OF CHRIST
NON-COMMUNITY, TRANSIENT PWS
PWS ID # OH1546412

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During October-December 2011**

Dear Mr. Johnson:

Hanoverton Church of Christ is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - NEDO. Include a copy of each notice distributed, published or posted.

HANOVERTON CHURCH OF CHRIST
OCTOBER 11, 2011
PAGE 2

4. Monitor with at least five (5) routine samples in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 330-963-1293.

Sincerely,

A handwritten signature in cursive script, appearing to read "Cynthia M. Petretich" followed by a small flourish.

Cynthia M. Petretich
Environmental Specialist
Division of Drinking and Ground Waters

CMP/ams

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Columbiana County Health Department
Information Management Section, DDAGW, CO