

**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

F

January 4, 2011

RE: TRUMBULL COUNTY  
FOWLER TOWNSHIP  
FOWLER MOBILE HOME PARK  
2819 SODOM-HUTCHINGS ROAD  
NPDES PERMIT NO. OH0084140  
OHIO EPA PERMIT NO. 3PV00040

Mr. Lester Swetel  
Fowler Mobile Home Park  
2819 Sodom-Hutchings Road  
Fowler, Ohio 44418

Dear Mr. Swetel:

On December 6, 2010, this office conducted an inspection of the sanitary wastewater treatment plant serving the above referenced facility. Also present were Messrs. Richard Curl of the Trumbull County Health Department and Tomás Parry of this office. The purpose of the inspection was to obtain and review information in anticipation of renewal of the National Pollutant Discharge Elimination System (NPDES) discharge permit. The current permit for this facility expired on December 31, 2010. A draft copy of the renewal permit will be sent under separate cover. Any comments regarding the draft permit must be submitted in writing during the public notice period.

The current 12,000 gallon/day treatment system consists of an extended aeration activated sludge "package" plant, final settling tank, slow surface sand filtration, aerated sludge holding tank, and chlorination/dechlorination unit. The facility discharges to South Branch Yankee Creek.

At the time of the inspection, all treatment units appeared to be in operation. As evidenced in the picture below, the final effluent being discharged to the receiving stream appeared to be of satisfactory visual quality.

A review of the facility's Discharge Monitoring Reports (DMRs) received by Ohio EPA for the period, January 2009 – November 2010, indicate violations of the terms and conditions of the NPDES permit. The specific instances of noncompliance are as follows:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2009	001	Chlorine, Total Residu	1D Conc	0.038	.1	5/20/2009
September 2009	001	Chlorine, Total Residu	1D Conc	0.038	.05	9/2/2009
May 2010	001	Chlorine, Total Residu	1D Conc	0.038	.07	5/5/2010
August 2010	001	Chlorine, Total Residu	1D Conc	0.038	.05	8/18/2010
August 2009	001	Fecal Coliform	30D Conc	1000	1296.	8/1/2009

Northeast District Office  
2110 East Aurora Road  
Twinsburg, OH 44087-1924

330 | 963 1200  
330 | 487 0769 (fax)  
www.epa.ohio.gov

Mr. Lester Swetel  
Fowler Mobile Home Park  
January 4, 2011  
Page 2

Please inform this office, in writing, within 10 days of receipt of this notification as to the actions taken or proposed to address the above referenced violations and/or deficiencies. Please be advised that past or current acts of noncompliance can continue as subjects of future enforcement actions.

Should you have any questions or comments regarding this letter, please contact me at (330) 963-1196.

Respectfully,



Ermelindo Gomes  
Environmental Engineer  
Division of Surface Water

EG/mt

enclosure

cc: Rich Curl, Trumbull County Health Department

File: Semipublic/Trumbull County/Fowler Twp./Fowler MHP

