



State of Ohio Environmental Protection Agency

Northeast District Office

F

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

February 15, 2008

RE: TRUMBULL COUNTY  
HUBBARD TOWNSHIP  
VALLEY MOBILE HOME PARK  
5925 YOUNGSTOWN-HUBBARD ROAD  
NPDES PERMIT NO.OH0128953  
OHIO EPA PERMIT NO. 3PV00096

Mr. Todd Jones  
P.O. Box 669  
3546 Avanti Lane  
Uniontown, OH 44685

Dear Mr. Jones:

An inspection was conducted by the undersigned of the sanitary wastewater treatment plant serving the above referenced facility on January 8, 2008. The facility was represented by Mr. Kent Kelley, Park Manager. The purpose of the inspection was to evaluate the facility's compliance status with respect to the terms and conditions of the above-referenced National Pollutant Discharge Elimination System (NPDES) permit.

**Inspection Findings/Compliance Status**

The current 15,000 gallon/day treatment system consists of a flow equalization basin, extended aeration activated sludge "package" plant, final settling tank, slow surface sand filtration, sludge holding, and chlorination/dechlorination.

At the time of the inspection, the operation and maintenance of the treatment system appeared to be satisfactory. The final effluent was clear with no visual evidence of adverse impact in the downstream segment of the receiving stream.

The inspection did note a missing section of fence at the plant entrance (see attached picture). Mr. Kelley indicated that he was awaiting delivery of a wider maintenance gate to be installed in the opening. The gate should be installed as soon as practicable. In the interim, he was instructed to place a temporary construction fence around the opening to deter unauthorized access to the facility.

A review of the facility's monthly operating reports received by Ohio EPA for the period January 2006 through December 2007 indicate violations of the terms and conditions of the NPDES permit. The specific instances of noncompliance are as follows:

Numeric Effluent Violations						
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2006	001	Chlorine, Total Residual	1D Conc	0.019	.05	5/9/2006
March 2007	001	Dissolved Oxygen	1D Conc	5.0	4.6	3/27/2007
June 2006	001	Dissolved Oxygen	1D Conc	5.0	3.5	6/7/2006

Mr. Todd Jones  
 Valley Mobile Home Park  
 February 15, 2008  
 Page 2

Numeric Effluent Violations						
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2006	001	Dissolved Oxygen	1D Conc	5.0	3.9	6/20/2006
June 2006	001	Dissolved Oxygen	1D Conc	5.0	3.7	6/27/2006
January 2006	001	Dissolved Oxygen	1D Conc	5.0	3.7	1/24/2006
March 2006	001	Dissolved Oxygen	1D Conc	5.0	4.4	3/1/2006
March 2006	001	Dissolved Oxygen	1D Conc	5.0	2.01	3/8/2006
October 2006	001	Dissolved Oxygen	1D Conc	5.0	4.4	10/19/2006
September 2006	001	Dissolved Oxygen	1D Conc	5.0	4.5	9/5/2006
February 2006	001	Dissolved Oxygen	1D Conc	5.0	4.2	2/1/2006
February 2006	001	Dissolved Oxygen	1D Conc	5.0	2.7	2/8/2006
February 2006	001	Dissolved Oxygen	1D Conc	5.0	3.	2/15/2006
February 2006	001	Dissolved Oxygen	1D Conc	5.0	3.	2/25/2006
August 2007	001	Dissolved Oxygen	1D Conc	5.0	4.4	8/1/2007
May 2007	001	Dissolved Oxygen	1D Conc	5.0	4.	5/8/2007
June 2007	001	Dissolved Oxygen	1D Conc	5.0	3.7	6/5/2007
June 2007	001	Dissolved Oxygen	1D Conc	5.0	2.	6/19/2007
September 2007	001	Dissolved Oxygen	1D Conc	5.0	3.4	9/18/2007
September 2007	001	Dissolved Oxygen	1D Conc	5.0	4.6	9/25/2007
July 2007	001	Nitrogen, Ammonia (NH3)	1D Conc	2.25	3.87	7/3/2007
July 2007	001	Nitrogen, Ammonia (NH3)	30D Conc	1.5	3.87	7/1/2007

Monitoring/Reporting Violations						
Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
January 2006	001	Color, Severity	1/Day	1	0	01/31/2006
January 2006	001	Odor, Severity	1/Day	1	0	01/31/2006
January 2006	001	Turbidity, Severity	1/Day	1	0	01/31/2006
July 2006	001	Color, Severity	1/Day	1	0	07/13/2006
July 2006	001	Odor, Severity	1/Day	1	0	07/13/2006
July 2006	001	Turbidity, Severity	1/Day	1	0	07/13/2006
July 2007	001	Flow Rate	1/Day	1	0	07/01/2007
July 2007	001	Color, Severity	1/Day	1	0	07/04/2007
July 2007	001	Odor, Severity	1/Day	1	0	07/04/2007
July 2007	001	Turbidity, Severity	1/Day	1	0	07/04/2007
July 2007	001	Color, Severity	1/Day	1	0	07/31/2007
July 2007	001	Odor, Severity	1/Day	1	0	07/31/2007
July 2007	001	Turbidity, Severity	1/Day	1	0	07/31/2007
August 2007	001	Color, Severity	1/Day	1	0	08/29/2007
August 2007	001	Odor, Severity	1/Day	1	0	08/29/2007
August 2007	001	Turbidity, Severity	1/Day	1	0	08/29/2007
August 2007	001	Color, Severity	1/Day	1	0	08/30/2007
August 2007	001	Odor, Severity	1/Day	1	0	08/30/2007

Monitoring/Reporting Violations						
Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
August 2007	001	Turbidity, Severity	1/Day	1	0	08/30/2007
August 2007	001	Color, Severity	1/Day	1	0	08/31/2007
August 2007	001	Odor, Severity	1/Day	1	0	08/31/2007
August 2007	001	Turbidity, Severity	1/Day	1	0	08/31/2007
September 2007	001	Color, Severity	1/Day	1	0	09/27/2007
September 2007	001	Odor, Severity	1/Day	1	0	09/27/2007
September 2007	001	Turbidity, Severity	1/Day	1	0	09/27/2007
September 2007	001	Color, Severity	1/Day	1	0	09/28/2007
September 2007	001	Odor, Severity	1/Day	1	0	09/28/2007
September 2007	001	Turbidity, Severity	1/Day	1	0	09/28/2007
November 2007	001	Color, Severity	1/Day	1	0	11/28/2007
November 2007	001	Odor, Severity	1/Day	1	0	11/28/2007
November 2007	001	Turbidity, Severity	1/Day	1	0	11/28/2007
November 2007	001	Color, Severity	1/Day	1	0	11/29/2007
November 2007	001	Odor, Severity	1/Day	1	0	11/29/2007
November 2007	001	Turbidity, Severity	1/Day	1	0	11/29/2007
November 2007	001	Color, Severity	1/Day	1	0	11/30/2007
November 2007	001	Odor, Severity	1/Day	1	0	11/30/2007
November 2007	001	Turbidity, Severity	1/Day	1	0	11/30/2007
December 2007	001	Color, Severity	1/Day	1	0	12/24/2007
December 2007	001	Odor, Severity	1/Day	1	0	12/24/2007
December 2007	001	Turbidity, Severity	1/Day	1	0	12/24/2007
December 2007	001	Color, Severity	1/Day	1	0	12/25/2007
December 2007	001	Odor, Severity	1/Day	1	0	12/25/2007
December 2007	001	Turbidity, Severity	1/Day	1	0	12/25/2007
December 2007	001	Color, Severity	1/Day	1	0	12/27/2007
December 2007	001	Odor, Severity	1/Day	1	0	12/27/2007
December 2007	001	Turbidity, Severity	1/Day	1	0	12/27/2007
December 2007	001	Color, Severity	1/Day	1	0	12/28/2007
December 2007	001	Odor, Severity	1/Day	1	0	12/28/2007
December 2007	001	Turbidity, Severity	1/Day	1	0	12/28/2007
December 2007	001	Color, Severity	1/Day	1	0	12/31/2007
December 2007	001	Odor, Severity	1/Day	1	0	12/31/2007
December 2007	001	Turbidity, Severity	1/Day	1	0	12/31/2007

**Summary/Conclusion**


Please be advised that failure to comply with the terms and conditions of your NPDES permit may be subject to enforcement actions pursuant to Chapter 6111 of the Ohio Revised Code. Such actions can result in fines of up to \$10,000 per day of violation. Please inform this office, in writing, within 10 days of receipt of this notification as to the actions taken or proposed to

Mr. Todd Jones  
Valley Mobile Home Park  
February 15, 2008  
Page 4

address the above violation and/or deficiencies. Your response **shall** include specific dates for completion of the actions. Please be advised that past or present issues of noncompliance can continue as subjects of future enforcement actions by Ohio EPA.

Should you have any questions or comments regarding this letter, please contact me at (330) 963-1196.

Respectfully,



Ermelindo Gomes  
Environmental Engineer  
Division of Surface Water

EG/mt

enclosure

cc: Brian Mosko, Valley Environmental Labs, Inc.  
Kent Kelley

File: Semipublic/Trumbull County/Hubbard Twp./Valley MHP

01/08/2008 15:00:23

