




**Environmental
Protection Agency**

Fed Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korteck, Director

OH6201911

Lake Erie Utilities Company

9/8/2010



Re: Ottawa County
Lake Erie Utilities
TNC Water System
PWS ID# OH6201911

September 8, 2010

Mr. Jim Arvin, President
Lake Erie Utilities, Inc.
P. O. Box 29
Middle Bass, Ohio 43446

Dear Mr. Arvin:

The May 2010 Drinking Water Contaminant/Operation Reports (EPA 5002 and 5109) for Lake Erie Utilities are incomplete. The lowest residual disinfection at the entrance to the distribution was not obtained and 0.2 mg/l free chlorine or 1.0 mg/l combined chlorine were not maintained in the distribution system. This constitutes a violation of Ohio Administrative Code (OAC) 3745-83-01(G)(1).

If you have any questions regarding this letter, please contact me at (419)373-3106.

Yours truly,

Debbie Ko
Division of Drinking and Ground Waters

/cs

pc: Derrick Chennault, Operator
Ottawa County Health Department
DDAGW, NWDO File

C

C