



**Environmental
Protection Agency**

OH2000903

Ayersville

7/21/2010

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



Re: Defiance County
Ayersville Water & Sewer District
Community Water System
PWS ID# OH2000903
STU ID# 2053836

July 21, 2010

Mr. John Sindell, President
Ayersville Water & Sewer District
13961 Fruit Ridge Road
Defiance, Ohio 43512

RE: Notice of Violation – Quarterly Operating Report

Dear Mr. Sindell:

The Ohio EPA, Division of Drinking and Ground Waters (DDAGW), Total Chlorine Residual Quarterly Operating Report (EPA 5114, revised April 2004) (QOR) for the April to June 2010 Quarter was received late on July 20, 2010.

Disinfection residual measurements are required to be taken for **total chlorine** according to Ohio Administrative Code (OAC) Rules 3745-81-70 (E) at the same time total coliform bacterial samples are collected. The total chlorine residuals obtained during routine and repeat total coliform bacterial monitoring events are to be reported on the QOR by the 10th of the month following the end of the calendar quarter being reported. [i.e. The July - September calendar quarter should be submitted to the district office no later than October 10th.] The operational report is to be signed by the operator in responsible charge designated in accordance with rule 3745-7-02 of the Administrative Code.

The Division of Drinking and Ground Waters has started a web-based monthly report reporting site called eDWR. It may be more convenient for you to submit the monthly reports using eDWR. More information regarding this can be obtained at <http://www.epa.ohio.gov/ddagw/reporting.aspx#edwr>.

Failure to take action to address this violation may result in enforcement action being taken.

If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3089 or via e-mail to jill.schiefer@epa.state.oh.us.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/cs

pc: Defiance County Health Department
DDAGW, NWDO File

(

(