



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Seneca County
Ruffing Family Care Center
Community Water System
PWS ID# 7400912


January 7, 2009

OH7400912

Ruffing Family Care Center

1/7/2009

Ms. Dianna Ruffing
Ruffing Family Care Center
2320 W County Road 6
Tiffin, OH 44883



Dear Ms. Ruffing:

The Ohio Environmental Protection Agency (Ohio EPA), Drinking Water Plant - Distribution Monthly Operation Report (EPA 5002) (MOR) was received for your public water system for November 2008.

Chlorine residual must be maintained throughout the entire distribution system at a minimum of 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine in accordance with OAC Rule 3745-83-01(C)(1). There were 9 days during the month of November that the minimum chlorine residual was not maintained throughout the distribution system.

Ruffing Family Care Center is in violation of OAC Rule 3745-83-01(C)(1) for not maintaining the minimum chlorine residual throughout the entire distribution system for the month of November 2008.

If you have any questions as a result of this letter, please contact me at (419) 373-3101.

Sincerely,

Ben Smith
Environmental Specialist 2
Division of Drinking and Ground Waters

/lb

pc: Joe Weincek, Operator, Ruffing Care Center
Toni Buchanan, IMS, DDAGW, CO
Seneca County Health Department
DDAGW, NWDO File