



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

November 7, 2012

Mr. Todd M. Hoffman
Crestline City
100 North Seltzer Street
Crestline, Ohio 44827-1949

Crawford County
Crestline City
Community PWS
PWS ID: OH1700112

Dear Mr. Hoffman:

In violation of OAC 3745-82-02, the Crestline City public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were four (4) weeks during the month in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

If you have any questions, please contact me at (419) 373-3108.

Sincerely,

A handwritten signature in cursive script that reads "Janis D'Amico".

Janis D'Amico
Division of Drinking and Ground Waters

/cg

pc: DDAGW – NWDO

