


John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

November 7, 2012

Dave Carnevale
P.O. Box 133
Plain City, OH 43064

Union County
Ranco North America LP
NON-TRANSIENT NON-COMMUNITY PWS
PWS ID: OH8033512

Dear Public Water System Owner:

This letter is notification that Ranco North America LP is in violation of OAC 3745-83-01 (C)(1) for September 2012, as the public water system failed to maintain the minimum required (free/combined) chlorine residual in the distribution system and at the plant tap. Multiple samples were less than the required two-tenths milligram per liter free chlorine or one milligram per liter combined chlorine. There were 5 days during the month in which the minimum chlorine residual was not maintained at the plant tap and seventeen days in which the minimum chlorine residual was not maintained in the distribution system.

This violation does not require public notification. It is also understood the water system is considered inactive as of November 1, 2012.

If this information is incorrect, or if you have any questions, please contact me directly at (614) 728-3863.

Respectfully,

Katie A. Anderson, E.I.
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)

KA/cl 8033512MOR(MI)SEP12