



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

November 7, 2012

Christopher Cook
P.O. Box 362
Gratiot, OH 43740

**Licking County
East End Water Co
COMMUNITY PWS
PWS ID: OH4566112**

Dear Public Water System Owner:

This letter is notification that East End Water Co. is in violation of the Ohio Administrative Code (OAC) 3745-83-01(G) (1) for September 2012, as the public water system failed to monitor for free or combined chlorine at least once every day that water is available to the public at each entry point to the distribution system and a representative point or points in the distribution system. There were no samples taken at the entry point during the month.

This violation does not require public notification. However, please review your operations to determine the reason for the missing analyses and advise this office as to what corrections will be made.

If you have any questions, please contact me directly at (614) 728-3863.

Respectfully,

Katie A. Anderson, E.I.
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)

KA/cl 4561112VOR(MI)SEP12