



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

November 7, 2012

RJ Edwards
Edwards Realty Company
5555 Wall Street
Dublin, OH 43017

**Licking County
El Rancho Mobile Home Park
COMMUNITY PWS
PWS ID: OH4500512**

Dear Public Water System Owner:

This letter is notification that the El Rancho Mobile Home Park is in violation of OAC 3745-83-01 (F)(2) for September 2012, as the public water system failed to report chlorine residual (free or combined) daily in the distribution system. There were 3 days during the month in which the analysis was not performed.

El Rancho Mobile Home Park is also in violation of OAC 3745-83-01 (F)(2) for failing to monitor for free or combined chlorine residuals at the entry point to the distribution sample. No entry point residuals were recorded during September 2012.

This violation does not require public notification. However, please review your operations to determine the reason for the missing analyses and advise this office as to what corrections will be made. Also, please note the water treatment plant production values are to be entered in millions of gallons per day (MGD). Please ensure the future entries are entered properly in the future.

If you have any questions, please contact me directly at (614) 728-3863.

Respectfully,

Katie A. Anderson, E.I.
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)

KA/vt 4500512MOR(M)SEP12