



State of Ohio Environmental Protection Agency

Northeast District Office

F

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 25, 2009

RE: SKYLAND HILLS MOBILE HOME PARK
STARK COUNTY
3IY00161 *BD

Mr. Leonard Cooper, President
Skyland Hills Mobile Home Park
P.O. Box 36177
Canton, OH 44735

Dear Mr. Cooper:

On June 22, 2009, this writer conducted a compliance evaluation inspection (CEI) of the treatment system which serves your water treatment plant. The treatment system consists of surface sand filters and a tablet dechlorinator.

At the time of the inspection, the sand filter beds contained excessive vegetation which needs to be removed. The tablet dechlorinator did not contain any dechlorination tablets.

A review of your discharge monitoring reports (DMRs) covering the period October 2007 through May 2009 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
October 2007	001	Total Suspended Solids	30D Conc	30	185.	10/1/2007
October 2007	001	Total Suspended Solids	30D Qty	0.65	1.05034	10/1/2007
October 2007	001	Total Suspended Solids	1D Conc	45	185.	10/17/2007
October 2007	001	Total Suspended Solids	1D Qty	0.97	1.05034	10/17/2007
February 2009	001	Total Suspended Solids	30D Conc	30	32.	2/1/2009

Please respond to this office, in writing, when the above deficiencies have been corrected.

The current NPDES permit for this facility will expire on November 30, 2009. The renewal NPDES permit for this facility will be public noticed in the near future. You will have 30 days from the date of public notice to submit written comments to Ohio EPA regarding the draft permit.

Should you have any questions or comments regarding this letter, please feel free to contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mt

Enclosure

cc: Dennis Clapper

File: Industrial/Permit Compliance





Surface sand filter beds.