





John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Lucas County
Oak Openings –Horse Center Area
TNC Water System
PWS ID # OH4844012

November 8, 2012

Mr. Russ Maneval
4139 Girdham Road
Swanton, Ohio 43558

Dear Mr. ^{Maneval} ~~Heckman~~:

This letter will confirm removal of the water use advisory required in our letter dated October 30, 2012. This is based on one set of four total coliform negative (safe) samples collected October 30, 2012, and received by our office on November 1, 2012.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by November 21, 2012.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of November 2012.

Yours truly,

A handwritten signature in black ink, appearing to read "Elizabeth Ames".

Elizabeth Ames
Division of Drinking and Ground Waters

/l/r

pc: Lucas County Health Department
DDAGW, NWDO

