



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



November 8, 2012

Fred W. Wright
Wilkins Mobile Home Park
200 Second Street NE
Mary Ann Township
Newark, OH 43055

Licking County
Wilkins Mobile Home Park
Community PWS
PWS ID: OH4503312

VIO ID: 9677318

Subject: Rescinding Violation – TCR

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on October 30, 2012 for the monitoring period of September 2012. The sample was collected on September 5, 2012 but the result was not reported until November 7, 2012.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued at this time. OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The sample was not reported in accordance with the above rules and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact this office at (614) 728-3863.

Sincerely,

Katie Anderson, E.I.
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

c: Licking County Health Department
Ohio Department of Agriculture Consumer Analytical Lab
District Office File

KA/cl 4503312(Rescind26)Sep2012