



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 14, 2011

Ms. Amy Ammon, General Manager  
Biederman Educational Centers. Inc.  
P.O. Box 488020  
Cincinnati, Ohio 45211

Re: Hamilton County, Beiderman Educational Centers, Inc., NPDES Permit Violations

Dear Ms. Ammon:

The Ohio EPA has completed a compliance evaluation of the Data Monitoring Reports (DMR) covering the months of January through April 2011 for the Biederman Educational Centers, Inc.. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0112461; OEPA Permit # 1PZ00051\*BD). The specific instances of noncompliance are as follows:

Reporting Violation			
Reporting Period	MOR Load Date	Reporting Lab	MOR Header
April 2011	5/23/2011	Beckman Environmental	1PZ00051*BD 001 2011-04 Original E 175134

Final Effluent Violations						
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date	
March 2011	TSS	Daily Conc	18	20	3/2/2011	
March 2011	TSS	Daily Conc	18	84	3/3/2011	
March 2011	TSS	Daily Conc	18	36	3/4/2011	
March 2011	TSS	Monthly Conc	12	47	3/1/2011	
March 2011	Ammonia	Daily Conc	4.5	6.8	3/3/2011	
March 2011	Ammonia	Daily Conc	4.5	7.9	3/4/2011	
March 2011	Ammonia	Monthly Conc	3.0	6.4	3/1/2011	
March 2011	CBOD	Daily Conc	15	20	3/2/2011	
March 2011	CBOD	Daily Conc	15	35	3/3/2011	
March 2011	CBOD	Daily Conc	15	15.2	3/4/2011	
March 2011	CBOD	Monthly Conc	10	23	3/1/2011	

Reporting Code Violation					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2011	Temperature			AB	3/9/2011
March 2011	Temperature			AB	3/16/2011
March 2011	Temperature			AB	3/23/2011

Please be advised that the electronic submittal of the monthly Data Monitoring Report is required to be submitted by no later than the 20<sup>th</sup> day of the month following the month of interest. It should also be noted that the use of the "AB" code requires an explanation to be provided in the comment section of the entry.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations.

Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at [Robert.Ostendorf@epa.state.oh.us](mailto:Robert.Ostendorf@epa.state.oh.us).

Sincerely,



**Bob Ostendorf Jr.**  
Division of Surface Water  
Permit Section