



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 23, 2009

Ms. Amy Ammon, General Manager  
Biederman Educational Centers. Inc.  
P.O. Box 488020  
Cincinnati, Ohio 45211

Re: Hamilton County, Biederman Educational Center, Notice of Violation

Dear Ms. Ammon:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of May 2009 through August 2009 for the Biederman Educational Center. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0112461; OEPA Permit # 1PZ00051\*BD). The specific instances of noncompliance are as follows:

Effluent Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2009	Ammonia	Daily Conc	1.5	4.5	6/1/2009
June 2009	Ammonia	Monthly Conc	1.0	19	6/1/2009
June 2009	Ammonia	Daily Conc	1.5	15	6/2/2009
June 2009	Ammonia	Daily Conc	1.5	23	6/3/2009
June 2009	pH	Daily Conc	6.5	6.4	6/3/2009
June 2009	Chlorine	Daily Conc	0.019	0.06	6/17/2009
June 2009	Ammonia	Daily Conc	1.5	36	6/18/2009
August 2009	Ammonia	Daily Conc	1.5	7.6	8/1/2009
August 2009	Ammonia	Monthly Conc	1.0	7.6	8/1/2009
August 2009	Ammonia	Daily Qty	0.01	0.02	8/1/2009
August 2009	Ammonia	Monthly Qty	0.01	0.02	8/1/2009


Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

Ms. Amy Amonn  
September 23, 2009  
Page 2

If you have any questions regarding this matter please feel free to contact me at (937) 285-6107 or via email at: [Robert.Ostendorf@epa.state.oh.us](mailto:Robert.Ostendorf@epa.state.oh.us).

Sincerely,

A handwritten signature in black ink that reads "Bob Ostendorf Jr." with a stylized flourish at the end.

Bob Ostendorf Jr.  
Division of Surface Water  
Permit Section

cc: Mr. John Beckman, Beckman Environmental