



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



November 8, 2012

Jeremy Hales
Skyview Baptist Ranch
7241 Twp. Rd. 319
Millersburg, OH 44654

HOLMES COUNTY
SKYVIEW BAPTIST RANCH
NON-COMMUNITY, TRANSIENT PWS
PWS ID # OH3836812
VIO ID # 8278404

Subject: Rescinding Violation – TCR

Dear Mr. Hales:

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on 10/22/2012 for the monitoring period of 3Q2012. The sample was collected on 9/13/2012 but the result was reported to the wrong public water system.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The sample(s) was (were) not reported in accordance with the above rules and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact this office at 330-963-1121.

Sincerely,

Leonard R. Rychlik, P.E.
Environmental Specialist
Division of Drinking and Ground Waters

LRR/ams

cc: Holmes County Health Department
Masi Laboratory