



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



November 14, 2012

Mr. Eric C. Thomas
Coldwater Village
610 West Sycamore Street
Coldwater, Ohio 45828

Mercer County
Coldwater Village
Community PWS
PWS ID: OH5400112
VIO ID: 7665012

Subject: Rescinding Violation – TCR


Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on October 7, 2011 for the monitoring period of August 2011. The sample was collected on August 16, 2011 but the result was not reported until November 8, 2012.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The sample was not reported in accordance with the above rules and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact me at (419) 373-3088.

Sincerely,



John A. (Jack) Schwartz
Division of Drinking and Ground Waters

/cg

pc: Mercer County Health Department
Belmont Laboratories
DDAGW – NWDO

ec: Kathy Pinto, DDAGW, CO