




Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

August 29, 2012

Wendy Nelsen  
5965 Harrisburg-Georgesville Road  
Grove City, OH 43123

Franklin County  
Oak Hills Mobile Home Park  
COMMUNITY PWS  
PWS ID: OH2502112

Dear Ms. Nelson:

Oak Hills MHP is in violation of Ohio Revised Code Chapter 6109 in July, 2012 as follows:

In violation of OAC 3745-83-01 (F)(2), the public water system failed to **report free or combined chlorine** residual daily at the plant tap. There were 4 days during the month in which the analysis was not performed.

In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the **minimum required free or combined chlorine residual** in the distribution system when the residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than 0.2 mg/L free chlorine or 1.0 mg/L combined chlorine. There were 3 days during the month in which the minimum chlorine residual was not maintained.

In violation of OAC 3745-82-02, the public water system has **exceeded the secondary standard for manganese** which is 0.05 mg/L. There were 2 weeks during the month in which manganese exceeded the secondary standard. Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)

Wendy Neisen  
Page -2-

These violations do not require public notification but Oak Hills MHP must take immediate action to resolve them. Please review your operations to determine the reason for the exceedances and advise this office as to what corrections will be made within 10 days of the date of this letter.

If you have any questions, please call me at 614-728-3864.

Sincerely,



Carolyn O'Neal  
Environmental Specialist III  
Division of Drinking and Ground Waters  
Central District Office

cc/pc: John Kinder, Operator of Record  
Franklin County Health Department  
IMS, DDAGW, CO  
AA, DDAGW, CDO  
CDO File  
eDoc