



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

November 16, 2012

NOTICE OF VIOLATION

RE: PORTAGE COUNTY
SOUTHEAST HIGH SCHOOL
NTNC WATER SYSTEM
PWS ID # OH6753512

Mr. Henry Michael
8245 Tallmadge Rd
Ravenna, Ohio 44266

Dear Mr. Michael:

This letter is notification that the Southeast High School public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01(F)(2)(a) which states, "A public water system that provides water treated with chlorine shall monitor for free or combined chlorine at least once every day that water is available to the public **at each entry point** to the distribution system and a representative point or points **in the distribution** system."

This violation of the OAC is based upon information submitted by the Southeast High School PWS as reported on Monthly Operating Report (MOR) #5002 for the month of **September 2012**. Below is a table which indicates the reporting months and the number of days when the free chlorine residual was not recorded.

Reporting Month	Number of days the free chlorine residual was reported at entry point	Number of days the free chlorine residual was <i>not</i> reported in distribution
June	0	13
July	0	14
August	0	15
September	0	10

Please provide a written explanation within 30 days of the date of this letter detailing how this issue is being addressed.

If you have any questions, please contact me directly at (330) 963-1182.

Respectfully,

Laurel Ljubi
Environmental Specialist
Division of Drinking and Ground Waters

LL/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Kim Eters, Ohio EPA, NEDO, DDAGW