



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

November 19, 2012

Mr. Craig Cordle
3290 US Highway 42 SW
London, OH 43140

**Madison County
Cordles Mobile Home Park
COMMUNITY PWS
PWS ID: OH4900312**

Dear Mr. Cordle:

The Public Water System serving CORDLES MOBILE HOME PARK is in violation of the Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), for failure to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. According to your October 2012 Monthly Operating Report there were 17 days when adequate chlorine residuals were not maintained.

Please increase your chlorine residuals so that adequate levels are consistently maintained throughout the entire distribution system of the park.

If you have any questions please call my office at (614) 728-3870.

Sincerely,

Bridgette Marchio
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)

BM/ct 4900312(M)Oct2012