



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



December 3, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Robert Kurtz
City of Vermilion
5511 Liberty Avenue
Vermilion, Ohio 44089

Erie County
City of Vermilion
Community PWS
PWS ID: OH2201511

Subject: Notice of Violation – Monthly Operating Reports

Dear Mr. Kurtz:

This letter is in regards to initial monthly operating reports for the City of Vermilion. Reports have been submitted incomplete and incorrect for the months of September and October, 2012.

In violation of OAC Rule 3745-83-01 (H) (1), the City of Vermilion failed to correctly report the percentage of time the filtered water exceeded the 0.3 NTU standards for the September, 2012 monitoring period.

In violation of OAC Rule 3745-81-75(C) (4), the City of Vermilion failed to correctly report the effective disinfectant contact time for 09/01/2012 through 09/13/2012.

In violation of OAC Rule 3745-83-01 (H) (1) (a), the City of Vermilion failed to correctly report the average turbidity for September 01 through September 13, 2011.

In violation of OAC Rule 3745-81-75(C) (4), the City of Vermilion reported incorrect required contact time values for the October, 2012 monitoring period.


In violation of OAC Rule 3745-81-77 (G) (1) and 3745-83-01 (H) (1), the City of Vermilion failed to correctly report the calculated TOC Value for the month of September, 2012.

Provide the lab reports for the TOC, Raw and finished, for the first nine days of September 2012, monitoring period.

Mr. Robert Kurtz
December 3, 2012
Page 2

If you have any questions regarding this letter, please contact me at (419)373-3103.

Sincerely,



Musa A. Khaleq, P.E.
Environmental Engineer 2
Division of Drinking and Ground Waters

/lr

pc: Erie County Health Department
Donald Daley, Uni-Tech Environmental
Paul Brock, P.E., DDAGW, NWDO
Toni Buchanan, DDAGW, CO
DDAGW, NWDO File

ec: Andy Barienbrock, DDAGW, CO