



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



November 1, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Ms. Betty Hosta
Kil-Kare Incorporated 2
1166 Dayton-Xenia Road
Xenia, Ohio 45385

**RE: GREENE COUNTY
KIL-KARE INCORPORATED 2
NON-COMMUNITY, TRANSIENT PWS
PWS ID: OH2956312**

Subject: Failure to Sample Drinking Water for Total Coliforms as Required

Dear Public Water System Operator:

Kil-Kare Incorporated 2 is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

Monitoring Period: Third Quarter of 2012
Required Coliform Monitoring: 1 routine per Quarter
Sample Results Submitted: Zero

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

ACTION REQUIRED:

- 1. Notify the people served by this water system using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.**

Timing: As soon as practical, but no later than 30 days after learning of the violation:

- Posting in conspicuous location, such as bulletin boards, restrooms, drinking fountains, vending areas;
- Mail or other direct delivery to each customer;
- Newsletters or newspaper;

Kil-Kare Incorporated 2
November 1, 2012
Page 2


- Email to employees or students;
- Send to parents or guardians of children at schools or day care facilities;
- Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in *italics* on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

2. Complete the enclosed Verification Form within 10 days of issuing the Public Notice and mail it to Ohio EPA - SWDO. Include a copy of each notice distributed, published or posted.

If total coliform samples were collected as required, submit the results as soon as possible. The monitoring violation will be rescinded and a reporting violation given for late submittal of the results.

If you have any questions, please contact me at (937) 285-6451.

Sincerely,



Dan Osika
Environmental Specialist
Division of Drinking and Ground Waters
Public Drinking Water Unit

Enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

cc: Greene County Health Department

DO\bp