



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 6, 2012

RE: GEAUGA COUNTY
JACQUES MOBILE HOME PARK
COMMUNITY WATER SYSTEM
PWS ID #OH2801812

Ms. Lynn Granata
990 Beach Ave, Suite 114
Vancouver, BC V6Z2N9

SUBJECT: NOTICE OF VIOLATION FOR CHLORINE SAMPLING

Dear Ms. Granata:

On November 5, 2012, this office received the *October, 2012 Monthly Operating Report* (MOR form 5002) from Jacques Mobile Home Park. The MOR is provided as a means to relay compliance information about the operation of the water treatment plant. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since Jacques Mobile Home Park treats its water by chlorine injection (disinfection), you are required to conduct monitoring for chlorine residuals.

Please note the following violation:

OAC Rule 3745-83-01(F)(2) requires either 1) free chlorine residual or 2) combined chlorine residual to be measured:

- 1) At the plant tap,
- 2) At a representative point in distribution, and
- 3) Measured every day that water is being produced.

JACQUES MOBILE HOME PARK
DECEMBER 6, 2012
PAGE 2 OF 2

Currently, your public water system is not collecting free chlorine residual and combined chlorine residual samples at the plant tap every day that water is being produced. In the October 2012 monthly operating report, it appears that chlorine is not being analyzed at the plant tap on the weekends. **Begin immediately to collect free chlorine residual or combined chlorine residual at the plant tap every day that water is being produced, to avoid notices of violation.** Please note that the chlorine samples do not have to be collected by the designated operator. Chlorine samples may be collected by the owners, or a resident within the mobile home park.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1149 or at my e-mail address, kathy.metropulos@epa.state.oh.us.

Sincerely,



Kathy Metropulos
Environmental Specialist
Division of Drinking and Ground Waters

KM:ds

pc: Geauga County Health Department
Kim Ethers, Ohio EPA, DDAGW-DW, NEDO
Ms. Carolyn Loschiavo
Mr. Josh Goodridge

ec: Stivo DiFranco, Ohio EPA, DDAGW-DW, NEDO
Kathy Metropulos, Ohio EPA, DDAGW-DW, NEDO