



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 21, 2010

Re: Pretreatment
Tastee Apple
Village of Newcomerstown
Permit No. ODP00025*CP
Noncompliance Notification

Mr. Jerry Herbert, Vice President of Manufacturing
Tastee Apple, Inc.
60810 County Road 9
Newcomerstown, Ohio 43882

Dear Mr. Herbert:

We have received your industrial user monitoring reports for the January through June 2009 and July through December 2009 reporting period. Our review indicates violations of the conditions of your Indirect Discharge Permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
002	00402	pH, Minimum	1D Conc	5.5	4.4	10/8/2009
002	00402	pH, Minimum	1D Conc	5.5	4.31	10/15/2009
002	00402	pH, Minimum	1D Conc	5.5	3.88	10/22/2009
002	00402	pH, Minimum	1D Conc	5.5	5.43	11/20/2009
002	00550	Oil and Grease, Total	1D Conc	100	149	10/29/2009

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your Indirect Discharge Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within thirty days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5423.

Sincerely,

A handwritten signature in cursive script that reads "Fred J. Snell". The letters are fluid and connected, with a prominent "F" and "S".

Fred J. Snell
Pretreatment Coordinator
Division of Surface Water

FJS/dh

c: Tom Sauerbrey, Utilities Director, Village of Newcomerstown
c: Pretreatment Unit, DSW, CO