



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 9, 2009

**Re:** Pretreatment  
Tastee Apple  
Permit No. 0DP00025\*CP  
Village Of Newcomerstown  
Noncompliance Notification

Mr. Jerry Herbert, Vice President of Manufacturing  
Tastee Apple, Inc.  
60810 County Road 9  
Newcomerstown, Ohio 43882

Dear Mr. Herbert:

We have received your industrial user monitoring reports for the July through December 2008 reporting period. Our review indicates violations of the conditions of your Indirect Discharge Permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00402	pH, Minimum	1D Conc	5.5	4.41	9/18/2008
002	00402	pH, Minimum	1D Conc	5.5	2.91	10/2/2008
002	00402	pH, Minimum	1D Conc	5.5	3.87	11/13/2008

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your Indirect Discharge Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5423.

Sincerely,

Fred J. Snell  
Pretreatment Coordinator  
Division of Surface Water

FJS/dh

c: Tom Saurbrey, Utilities Director, Village of Newcomerstown  
c: Pretreatment Unit, DSW, CO