

**The stream near the cemetery is receiving a large amount of sediment from the disturbed slope above. The area appeared to be at final grade. Apply permanent stabilization immediately. Assess the entire site and apply stabilization all barren areas as needed according to the above permit requirements.**

In accordance with the permit (Part II. D.), the permittee shall make the NOI and SWP3 available upon the request of the director of Ohio EPA or authorized representative; local agencies approving sediment and erosion control plans, grading plans, or storm water management plans; local government officials; or operators of municipal separate storm water systems. Part III.C.2.a. requires the NOI application, letter of approval, and SWP3 to be available at the construction site upon the request of the director of Ohio EPA or his authorized representative.

**Send a copy of the SWP3 for review along with the response to this letter.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 380-5418 or Aaron Wolfe at (740) 380-5277.

Sincerely,



Chris Stephan  
Storm Water Section  
Division of Surface Water

CCS/dh

THE PREVIOUS LETTER  
CONTAINED AN INCORRECT  
DATE OF INSPECTION.  
THIS LETTER SERVES  
TO REPLACE THE PREVIOUS  
LETTER.