



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 21, 2011

**Re:** Athens County  
OU Ridges South Site Improvement Project  
Storm Water Construction Activity  
0GC01142\*AG

Mr. Jeff Maiden  
Ohio University  
1 Riverside Drive  
Room 170  
Athens, Ohio 45701

Dear Mr. Maiden:

On June 29, 2011 I visited the site located on Carriage Hill Drive that had a construction stormwater permit with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

**At the time of my inspection, the site was inactive and it appeared that construction activities had been completed.**

An NOT may be submitted to Ohio EPA if the following requirements have been fulfilled:

1. A perennial vegetative cover (or equivalent means of stabilization) has been established over 100% of the surface area disturbed during construction. The vegetative growth must be at a growth density of 70%.
2. All temporary sediment and erosion controls have been removed and properly disposed.
3. All sediment has been permanently stabilized to prevent further erosion.
4. Construction activity at the site has ceased.

It appears that you site meets the above criteria. If you agree, please submit an NOT within 45 days of the completion of construction activities. Failure to submit an NOT is a violation of the permit requirements and may affect your ability to obtain a NPDES permit in the future.

Please send the completed NOT to the following address:

Ohio Environmental Protection Agency  
Division of Surface Water  
Storm Water Section  
P.O. Box 1049  
Columbus, Ohio 43216-1049

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5418.

Sincerely,

A handwritten signature in black ink, appearing to read "Chris Stephan", with a stylized flourish at the end.

Chris Stephan  
Storm Water Section  
Division of Surface Water

CSS/dh

Enclosure: Notice of Termination