



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 9, 2009

Re: Belmont County
Barnesville Reservoir Dam
Storm Water Construction Activity
Notice of Violation
Permit Number OGC01305*AG

Roger Deal
Village of Barnesville
126 East church Street
Barnesville, OH 43713

Dear Mr. Deal:

On August 19, 2009, I visited your site on Waterworks Road in Barnesville. The purpose of the inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage


1. Part III.G.2.d.iii of the permit requires silt fence to be installed on a level contour. Silt fence should be utilized in accordance with the specification of the *Rainwater and Land Development* manual. **Please install silt fence around the disturbed areas depicted in the attached photographs. This will prevent erosion into the reservoir and onto the water treatment plant property.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277.

Please be advised that failure to comply with the terms and conditions of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael See", with a horizontal line extending to the right.

Michael See
Storm Water Section
Division of Surface Water

MS/mlm

Enclosures

c: Debra Prim, DDAGW/SEDO

