



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 31, 2009

**Re: Guernsey County
Basic Systems, Inc.
Stormwater Construction Activity
Notice of Violation
0GC01099*AG**

Mr. Gene Oliver
Cadiz Commercial Holdings LLC
10901 Clay Pike Road
Derwent, Ohio 43725

Dear Mr. Oliver:

On July 15, 2009, I visited your site on Cadiz Road in Cambridge. The purpose of the inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage:

1. Part III.G.2.b.i. of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance. Temporary seeding may be accomplished any time between March 1 and November 1. Any seeding that occurs between November 1 and the spring seed will be considered dormant seeding. **Several of the soil stock piles and nearby areas are in need of stabilization (see attached photos).**
2. Part V. N. of the permit states that all facilities and systems of treatment and control must be properly operated and maintained at all times. **The silt fence is damaged in several places (indicated by attached photos) please repair or replace the silt fence immediately.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5226.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael See". The signature is fluid and cursive, with a large initial "M" and a long, sweeping underline.

Michael See
Storm Water Section
Division of Surface Water

MS/dh

