



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 10, 2009

**Re: Hocking County
Chieftan Biofuels
Storm Water Construction Activity
Notice of Violation
Permit Number 0GC01124*AG**

Mr. Douglas Kitchen
Chieftan Biofuels
32919 Logan Hornsmill Road
Logan, Ohio 43138

Dear Mr. Kitchen:

On June 29, 2009, I visited your site on Logan Hornsmill Road in Logan. The purpose of the inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance. **Any dormant areas that meet these criteria need to be stabilized immediately.**
2. Part III.G.2.b.ii. of the permit states that operators shall stabilize channels and outfalls to prevent erosive flows. **Currently, the silt fence is not capable of treating the amount of water that is being discharged from the site, and the outflow is showing signs of erosion. This channel needs to be stabilized with rip rap or some other form of erosion control**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5226.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael See", with a long horizontal flourish extending to the right.

Michael See
Storm Water Section
Division of Surface Water

MS/dh