



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 17, 2010

**Re:** Jackson County  
Oak Hill Athletic Complex  
Storm Water Construction Activity  
Notice of Violation  
OGC00210\*AG

Mr. Tim McCoy  
Oak Hill Union Local School District  
5063 State Route 93  
Oak Hill, Ohio 45656

Dear Mr. McCoy:

On August 11, 2010, I visited your site on State Route 93 in Oak Hill. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

- 1. Part III.G.2.b. of the permit states:

**Table 1: Permanent Stabilization**

<b>Area requiring permanent stabilization</b>	<b>Time frame to apply erosion controls</b>
Any areas that will lie dormant for one year or more	Within seven days of the most recent disturbance
Any areas within 50 feet of a surface water of the State and at final grade	Within two days of reaching final grade
Any other areas at final grade	Within seven days of reaching final grade within that area

**Table 2: Temporary Stabilization**

<b>Area requiring temporary stabilization</b>	<b>Time frame to apply erosion controls</b>
Any disturbed areas within 50 feet of a surface water of the State and not at final grade	Within two days of the most recent disturbance if the area will remain idle for more than 21 days
For all construction activities, any disturbed areas that will be dormant for more than 21 days but less than one year, and not within 50 feet of a surface water of the State	Within seven days of the most recent disturbance within the area  For residential subdivisions, disturbed areas must be stabilized at least seven days prior to transfer of permit coverage for the individual lot(s).
Disturbed areas that will be idle over winter	Prior to the onset of winter weather


Where vegetative stabilization techniques may cause structural instability or are otherwise unobtainable, alternative stabilization techniques must be employed.

**Stabilization is needed on the barren areas at the top of the hill to the rear of the facility. Erosive flow is carrying sediment to the rear of the building, in order to solve this problem apply seed and straw on top of the hill immediately.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 380-5418 or Aaron Wolfe at (740) 380-5277.

Sincerely,



Chris Stephan  
Storm Water Section  
Division of Surface Water

CCS/dh