



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 5, 2009

Re: Lawrence County
Eric Riley
Stormwater Construction Activity
Notice of Violation
OGC00971*AG

Mr. Eric Riley
181 Private Road 865
South Point, Ohio 45680

Dear Mr. Riley:

On July 27, 2009, I visited your site on Kitts Lane in South Point. The purpose of the inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage:


1. Part III.G.2.b.i (Table 1) of the permit requires that permanent stabilization be applied to areas at final grade within 7 days of the last disturbance. Permanent stabilization is defined as the establishment of permanent vegetative cover, decorative landscape mulching, matting, sod, rip rap and landscaping techniques to provide permanent erosion control. **Please stabilize the areas of your yard around your house that are still bare. The main area would be on the bank opposite of your house.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5413.

Please be advised that failure to comply with the terms and conditions of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Sincerely,

A handwritten signature in cursive script that reads "Dustin Tschudy".

Dustin Tschudy
Storm Water Section
Division of Surface Water

DT/dh