



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 8, 2010

**Re: Lawrence County  
Ohio State Highway  
Patrol Ironton Post #44  
Storm Water Construction  
Notice of Violation  
0GC01325\*AG**

Mr. Thomas Ford  
Ohio Department of Public Safety  
1970 W. Broad Street, Suite 532  
Columbus, Ohio 43223

Dear Mr. Ford:

On March 15, 2010, I visited your site at 141 Township Road 161 in South Point, Ohio. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. Install a sediment trap to capture flows from the waste/fill area located near the entrance of the site. The sediment trap must be sized per permit requirements.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned Rainwater and Land Development manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 380-5277.

Sincerely,

Aaron Wolfe  
Storm Water Section  
Division of Surface Water

AW/dh