



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 17, 2010

**Re:** Lawrence County  
CVS Pharmacy #3474  
Storm Water Construction Activity  
Notice of Violation  
0GC01406\*AG

Mr. Jeff Albrecht  
Hometown Development Co.  
711 Second Street  
Portsmouth, Ohio 45622

Dear Mr. Albrecht:

On July 21, 2010, I visited your site on Jefferson Rd in Ironton. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. Construction Entrance

Part III.G.2.g.ii. of the permit requires that off-site vehicle tracking of sediments be minimized. This is accomplished by constructing a proper construction entrance. The *Rainwater and Land Development* manual defines a construction entrance as a pad of aggregate 6 inches deep, 10 feet wide and 50 feet in length (30 feet for single residence lots).

**Vehicles exiting the construction site are tracking dirt and gravel on to Jefferson Road. Fix this problem immediately.**

2. Silt Fencing


Part III.G.2.d.iii of the permit requires silt fence to be installed on a level contour. Silt fence should be utilized in accordance with the specification of the *Rainwater and Land Development* manual.

**The silt fencing along S. Third Street has broken down. Assess silt fencing throughout entire site and make repairs as necessary.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 380-5418 or Aaron Wolfe at (740) 380-5277.

Sincerely,

A handwritten signature in black ink, appearing to read "Chris Stephan", with a long horizontal flourish extending to the right.

Chris Stephan  
Storm Water Section  
Division of Surface Water

CCS/dh